

Office of the Civil Surgeon Cum Chief Medical Officer Muzaffarpur.

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No 4219

date 30-07-2021

It is Certified that an inspection team headed by Dr. Md. Hasib Asgar & Dr. C. S. Prasad both are Medical Officer (Name of Officers with Designation) from Sadar Hospital Muzaffarpur (Name of department /Office) inspected the Shemford Futuristics School , Dumari Muzaffarpur (Name & Address of the School) on 29-07-2021 and found that the Shemford Futuristics School , Dumari Muzaffarpur (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T Govt.

The above valid for a period of Three Years

Recd
29.7.21
W
29.7.21

Signature with Seal.....

30-7-21
CS Cum CMO
Muzaffarpur

Name

Dr. Binay Kumar Sharma

Designation

C.S. Cum CMO Muzaffarpur

To

Shemford Futuristics School ,

Dumari Muzaffarpur

(Name & Address of the institution)

Dayan

Principal

Shemford Futuristic School
Dumri, Muzaffarpur
School Code-65831
Affiliation No.-330826

Pida

Manager

Shemford Futuristic School
Muzaffarpur

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Test Report

Division Name :- P. H. Division, Muzaffarpur

District Name : Muzaffarpur

Month : August 2023

Name of the School :- SHEMFORD FUTURISTIC SCHOOL, DUMRI, MUZAFFARPUR

Testing Date	Block	Panchayat	Village	Habitat/ Ward	Location of Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	No ₃	So ₄	F	As	Total Cell	Remarks	
19.08.2023	Mushari	Dumri	Dumri	-	Near New Patna By Pass Road, Muzaffarpur	6.81	0.57	147.18	95.67	84.92	32.94	16.64	23.87	172.39	0.21	7.86	7.06	0.27	-	-	23	
	3-	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
	Desirable Limit **		6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	0.01	-	-	-	-	-	-
	Permissible Limit* in absence source (IS 10500-2012 - 2nd Revision		NR	5.0		2000	600	200	100	1000	600	1	NR	400	1.5	NR						

Drinking Water Specification First Revision -IS:10500:2012, Edition 2, 2003-09.12.20 (Reaffirmed 1993), (2) BDL = Below Detection Limit, (3) NR = No Relaxation, (4) ND = Not Done.

1) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml.

(d) Coliform organisms should not be detected in 100ml of any two consecutive samples.

warded for information to: (i) Consultant Water Quality Cell, PHED, Govt. of Bihar, (ii) Director, Water Quality Cell, PHED, Govt. of Bihar, (iii) SLWTL, PHED, Govt. of Bihar.

Manager
Shemford Futuristic School
Muzaffarpur

Chemist
R. W. T. L., Muzaffarpur

Principal
Shemford Futuristic School
Dumri, Muzaffarpur
School Code-65831
Affiliation No.-330826

Signature